

DG TYPE EXAMINATION CERTIFICATE

No.
DG-3376

This is to certify that:

Danish Institute of Fire and Security Technology, specified as a "notified body" under the terms of the Danish Safety Technology Authority, did undertake the relevant type approval procedures for the equipment identified below which was found to be in compliance with the Danish Gas Regulations, Section C-2, subject to any conditions in the description attached hereto.

Applicant SRG Schulz & Rackow Gastechnik GmbH
Address Industriestrasse 11, D-35075 Gladenbach, Germany
Type of Appliance LPG Gas Adaptor
Trade Mark SRG
Type/Model 652-1
Specified Standards EN 16129:2013

**The attached (*description of type approval*) forms part of this certificate.
This certificate remains valid unless cancelled or revoked, provided the conditions in the attached schedule are complied with and the equipment remains satisfactory in service.**

Date of issue 2016-03-29 Issued by Danish Institute of Fire and Security Technology
Notified Body No. **0845**

Signed



Name

Ken Olesen

Note:

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the notified body named on this certificate.



Subject to compliance with the conditions in the annex "Description of Type Approval", which forms part of this certificate, and those of the Regulations, the Manufacturer is allowed to affix the "Mark of Conformity" to the product described herein.

xxxx DG approval number

This certificate is issued under the authority of the Danish Safety Technology Authority.



(Annex)
Description of Type Approval

Product Description

Trade Marks SRG
Type/Model 652-1

Technical Data

Category: I_{3B/P} – LPG
Inlet pressure: 0.3 – 16 bar
Outlet pressure: Unreduced
Flow rate: 8.0 kg/h
Inlet connection: G56
Outlet connection: 3/8" BSP LH

Comments: -

Type Approval Documentation

Test report : TÜV certificate of conformance no. 36.AP.013.13a 2015-12-10 regarding compliance with:
- EN 16129:2013

End of Certificate